

# Off-line Inspection Checklist

## Vuspex GO

### Roof/Re-Roof

#### Required confirmation with pictures or videos

- Permit of site at time of inspection
- Property address number
- Measure the roof deck nailing with tape measure (6" o.c.) minimum two pictures per side
- Replacement wood decking or fascia if needed
- Valley flashing install if needed
- Drip edge installation nailing pattern show 4" of mastic, 4 sides
- Starter shingles if needed, nailing pattern

#### Dry in

- Pictures of all sides of the roof verifying the type of dry-in material use and how installed
- Check all vent boots, mastic as required
- Chimney and crickets, if present
- Rigid installation, if installed

#### Roof in progress

- Roofing type and identification, review packaging for installation standards
- Dry-in competed, 4 sides
- Attic vent type and fasteners completed, nailing pattern
- Fastener schedule for rigid insulation, if installed
- Base sheet for flat deck, verify slope of flat roof
- Attachment for tile roof (include adhesive/foam)
- Type of single ply or composition roofing used include manufacturer installation instructions

#### Final inspection

- Nailing pattern of roofing installed per manufactures installation standards
- Ridge caps installed per manufacture
- All boots installed and sealed