

Virtual Inspection Checklist

Electric for Water Heater Replacement

Required Images and Sequence -

- Permit on site
- Front elevation of home/business to verify address
- Temperature control set not to exceed 140 degrees
- Location of water heater, Pan maybe required
- Water heaters in Garages, with an ignition source, located that the source will be located 18" above the garage floor
- Pressure-relief and a temperature relief valve or a combination P/T valve are installed
- Discharge pipes to the outside or if in a garage, within 6" of the floor
- Wire size matches label on tank
- Main breaker panel, breaker sized correctly to match wire size
- Remote disconnects is line-of-sight
- Flex connections to units connected and bonded
- Expansion tank required if it's a closed system